



**CITY OF HOLLYWOOD
DEPARTMENT OF PUBLIC UTILITIES
ENGINEERING & CONSTRUCTION SERVICES DIVISION**

1621 N. 14th Avenue
Hollywood, FL 33022
Phone (954) 921-3930 Fax (954) 921-3258

ADDENDUM NUMBER 1

Date: **6/17/10**

FOR: **Pole Replacement Along the Broadwalk**

FILE NUMBER: **BCRA 10-013**

ALL BIDDERS BE ADVISED OF THE FOLLOWING CHANGES TO THE ABOVE REFERENCED PROJECT AS LISTED BELOW:

This addendum is issued as part of the Bidding Documents for the above described project. The changes incorporated in this addendum shall be considered as a part of the documents and shall supersede, amend, add to, clarify, or subtract from those conditions shown in the original documents dated 5/7/10. The bidder shall coordinate all modifications herein with all trades and disciplines related to the work. The Bidder shall acknowledge receipt of this addendum on the Bid Form by addendum number and date. Failure to do so may subject Bidder to disqualification.

Item 1: The weight of the new poles is approximately 1,750, 1,500 and 1,150 LBS.

Item 2: Paint: anodizing is not required. Paint shall be electro-statically powder coated.

ALL OTHER TERMS, CONDITIONS AND SPECIFICATIONS SHALL REMAIN THE SAME.

THIS ADDENDUM SHALL BE ATTACHED TO THE CONTRACT DOCUMENTS AND THE RECEIPT OF THE SAME SHALL BE NOTED IN THE PROPOSAL IN THE SPACE PROVIDED.

Jitendra Patel, P.E., Assistant Director
Department of Public Utilities - ECSD