



**CITY OF HOLLYWOOD
DEPARTMENT OF PUBLIC UTILITIES
ENGINEERING & CONSTRUCTION SERVICES DIVISION**

1621 N. 14th Avenue
Hollywood, FL 33022
Phone (954) 921-3900 Fax (954) 921-3462

ADDENDUM NUMBER 1

Date: July 2, 2010

FOR: Fred Lippman Multi-Purpose Center - New Fire Alarm System

FILE NUMBER: PR 10-011

ALL BIDDERS BE ADVISED OF THE FOLLOWING CHANGES TO THE ABOVE REFERENCED PROJECT AS LISTED BELOW:

This addendum is issued as part of the Bidding Documents for the above described project. The changes incorporated in this addendum shall be considered as a part of the documents and shall supersede, amend, add to, clarify, or subtract from those conditions shown in the original documents dated June 11, 2010. The bidder shall coordinate all modifications herein with all trades and disciplines related to the work. The Bidder shall acknowledge receipt of this addendum on the Bid Form by addendum number and date. Failure to do so may subject Bidder to disqualification.

Item 1: Fire Alarm Revisions

The fire alarm bid documents have been revised, as indicated on the attached revised drawing sht. FA-1, Revision #1, dated 6-29-2010 and specifications revisions as per attached Bray letter, dated 6-30-2010.

ALL OTHER TERMS, CONDITIONS AND SPECIFICATIONS SHALL REMAIN THE SAME.

THIS ADDENDUM SHALL BE ATTACHED TO THE CONTRACT DOCUMENTS AND THE RECEIPT OF THE SAME SHALL BE NOTED IN THE PROPOSAL IN THE SPACE PROVIDED.

**Steve Joseph, Deputy Director
Department of Public Utilities - ECSD**

NORMAN F. BRAY, P.E., INC. . . . CONSULTING ENGINEER

FLORIDA REGISTRATION NUMBER 9978
 FLORIDA CERTIFICATE OF AUTHORIZATION NUMBER 1124

2131 HOLLYWOOD BOULEVARD . SUITE 501 . BOULEVARD LANDMARK
 HOLLYWOOD, FLORIDA 33020-6753
 PHONE: (954) 925-3217 FAX: (954) 925-3247
 EMAIL: BRAY501@BELLSOUTH.NET

June 30, 2010

City of Hollywood
 Hollywood Public Works
 Engineering & Construction Services Division
 Attn: Steve Groh
 2717 Van Buren St.
 Hollywood, FL 33020-4819

PH. 954-921-3900

Fx. 954-921-3462

Re: Fred Lippman Fire Alarm Project
 NFB #10063

Dear Steve,

Please issue the following addenda items:

1. Drawing FA-1 – Revision #1, dated 6-29-2010, entirely revised.
2. Specifications
 - A. Section 16110, Paragraph 3.03
 Change the word "conduits" to "cables".
 - B. Section 13845, Paragraph 2.03, Delete
 Subparagraphs A3 and A4
 - C. Section 13845, Paragraph 2.06 A – Add the following
 "Additional manufacturers will be considered for approval."
 - D. Section 13845, Paragraph 2.07 B
 "Change the system requirements from "1000 points" to 100 points".
 - E. Section 13845, Paragraph 2.07, Delete Paragraph 2.07 S.
 - F. Section 13845, Paragraphs 3.03 and 3.04
 Approved and listed Fire Alarm cable may be used.

DEPARTMENT OF
 REGISTRATION
 2010 JUN 30 PM 1:00

Very truly yours,

NORMAN F. BRAY, P.E., Inc.



Norman F. Bray, P.E.
 Fla. Reg. #9978

NFB/sc