



**CITY OF HOLLYWOOD
DEPARTMENT OF PUBLIC UTILITIES
ENGINEERING & CONSTRUCTION SERVICES DIVISION**

1621 N. 14th Avenue
Hollywood, FL 33022
Phone (954) 921-3900 Fax (954) 921-3462

ADDENDUM NUMBER 2

Date: **July 26, 2010**

FOR: **Wastewater Treatment Plant Administrative Office Renovations**

FILE NUMBER: **DCM 09-002**

ALL BIDDERS BE ADVISED OF THE FOLLOWING CHANGES TO THE ABOVE REFERENCED PROJECT AS LISTED BELOW:

This addendum is issued as part of the Bidding Documents for the above described project. The changes incorporated in this addendum shall be considered as a part of the documents and shall supersede, amend, add to, clarify, or subtract from those conditions shown in the original documents dated July 9, 2010. The bidder shall coordinate all modifications herein with all trades and disciplines related to the work. The Bidder shall acknowledge receipt of this addendum on the Bid Form by addendum number and date. Failure to do so may subject Bidder to disqualification.

Item 1: Electrical Revision

Delete "New Panel 1R" and provide revised circuits as per the attached letter from Norman F. Bray, Inc., dated July 27, 2010.

ALL OTHER TERMS, CONDITIONS AND SPECIFICATIONS SHALL REMAIN THE SAME.

THIS ADDENDUM SHALL BE ATTACHED TO THE CONTRACT DOCUMENTS AND THE RECEIPT OF THE SAME SHALL BE NOTED IN THE PROPOSAL IN THE SPACE PROVIDED.

Jitendra Patel, P.E., Assistant Director
Department of Public Utilities - ECSD

NORMAN F. BRAY, P.E., INC. . . . CONSULTING ENGINEER

FLORIDA REGISTRATION NUMBER 9978
FLORIDA CERTIFICATE OF AUTHORIZATION NUMBER 1124

2131 HOLLYWOOD BOULEVARD . SUITE 501 . BOULEVARD LANDMARK
HOLLYWOOD, FLORIDA 33020-6753
PHONE: (954) 925-3217 FAX: (954) 925-3247
EMAIL: BRAY501@BELLSOUTH.NET

July 27, 2010

City of Hollywood
Hollywood Public Works
Engineering & Construction Services Division
Attn: Steve Groh, AIA
2717 Van Buren St.
Hollywood, FL 33020-4819

Re: SRWWTP – Administration Building
Our Job #10055

Dear Mr. Groh.

Please issue the following Addenda items:

Drawing E-1


1. Change the following circuit designations:
1R-2, 4 to 1L-29, 31
1R-6 to 1L-30
1R-7, 9 to 1L-32, 34
1R-8, 10 to 1L-33, 35
1R-12 to 1L-36
2. Add 8 new 20A-1P breakers in Panel 1L.
3. Delete "New Panel 1R" and update Panel 1L directory.

Drawing E-2

4. Delete Panel 1R and related notes.

Very truly yours,

NORMAN F. BRAY, P.E., Inc.



Norman F. Bray, P.E.
Fla. Reg. #9978

NFB/sc