



**CITY OF HOLLYWOOD  
DEPARTMENT OF PUBLIC UTILITIES  
ENGINEERING AND CONSTRUCTION SERVICES**

1621 N. 14<sup>TH</sup> Avenue  
Hollywood, FL 33022  
Phone (954) 921-3930 Fax (954) 921-3462

**ADDENDUM NUMBER 1**

Date: July 27, 2010

FOR: Information Technology – City Hall Computer Room – Air Conditioning Upgrades  
(Electrical Work Only)

FILE NUMBER: CM-09-005

ALL BIDDERS BE ADVISED OF THE FOLLOWING CHANGES AND OR CLARIFICATIONS TO THE ABOVE REFERENCED PROJECT AS LISTED BELOW: -

**Item 1:** Supplementary Conditions: Part 1- 1.05, Required Shop Drawings – delete the items listed and add the following:

Items

Panel Q  
Panel CDP  
Weatherproof Disconnect Switches  
Combination Switch/Starters  
Weatherproof GFCI Duplex Receptacles  
Wire and Conduit

**Item 2:** Replace spare 225 amp, 3 pole breaker #15 in Main Switchboard with a Square 'D' KA breaker with a 120 volt factory installed shunt trip.

**Item 3:** Replace Panel P – 200 amp, 3 pole breaker #22 in Main Switchboard with a square 'D' KA breaker with a 120 volt factory install shunt trip.

**Item 4:** Wire both new shunt trips in breakers #15 and #22 back to the Computer Room with 2 #12-1/2”C to an Emergency shutdown switch at the left side of the Computer Room Exit door, surface mounted. Provide a 120 volt source from a spare circuit in Panel CB, 20A-1P breaker.



**CITY OF HOLLYWOOD  
DEPARTMENT OF PUBLIC UTILITIES  
ENGINEERING AND CONSTRUCTION SERVICES**

1621 N. 14<sup>TH</sup> Avenue  
Hollywood, FL 33022  
Phone (954) 921-3930 Fax (954) 921-3462

**ADDENDUM NUMBER   1**

**Item 5:** Turn over two breakers removed from Main Switchboard to Public Works.

**Item 6:** Coordinate Main Switchboard shutdown to replace the two breakers.

**Item 7:** Remove Page 2 of Proposal Bid Form and insert the attached Page 2 of the Revised 7/26/2010 Proposal Bid Form

ALL OTHER TERMS, CONDITIONS AND SPECIFICATIONS SHALL REMAIN THE SAME.

THIS ADDENDUM SHALL BE ATTACHED TO THE CONTRACT DOCUMENTS AND THE RECEIPT OF THE SAME SHALL BE NOTED IN THE PROPOSAL IN THE SPACE PROVIDED.

Jitendra Patel, P.E., Assitant Director  
Department of Public Utilities



**CITY OF HOLLYWOOD  
DEPARTMENT OF PUBLIC UTILITIES  
ENGINEERING & CONSTRUCTION SERVICES DIVISION**

**PROPOSAL BID FORM  
(Revised 7/26/2010)**

8.	Feed the New Disconnects from Panel Q	1	LS	_____	_____
9.	Provide and Install Emergency Shut Down as Outlined in Items 2-6 of Addendum #1	1	LS	_____	_____
10.	OWNERS CONTINGENCY ALLOWANCE.	1	LS	_____	<u>\$5,000.00</u>

**BASE BID:** \_\_\_\_\_ \$ \_\_\_\_\_

\_\_\_\_\_  
Company Name:

\_\_\_\_\_  
Signature:

\_\_\_\_\_  
Date: